



Certificate of Compliance

Certificate: 1482323

Master Contract: 157944

Project: 80177329

Date Issued: 2023-09-19

Issued To: nVent Thermal Canada Ltd
250 West St
Trenton, Ontario, K8V 5S2
Canada

Attention: James Lim

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Issued by: Davinder Pal Singh
Davinder Pal Singh



PRODUCTS

CLASS 4418 05 - CABLE Hardware - For Hazardous Locations

CLASS 4418 85 - CABLE-Hardware For Hazardous Locations-Certified to U.S. Standards

Class I, Groups A, B, C, and D, Class II, Groups E, F, and G, Class III:

MI Cable termination for connection to threaded conduit openings, Series "PyroPAK", Cat. No. PPAK, Rain-tight, rated 300V or 600V, 90°C, 105°C, 150°C, and 250°C; trade sizes ½ in. to 1-1/4 in. NPT.

Note: Series Cat. No. PPAK is followed by alphanumeric suffixes to denote gland material, thread size, type of pot, cable diameter, temperature rating, number of conductors, conductor size, and tail length.



Certificate: 1482323
Project: 80177329

Master Contract: 157944
Date Issued: 2023-09-19

APPLICABLE REQUIREMENTS

CSA C22.2 No. 18.3-04	-	Conduit, Tubing, and Cable Fittings
CSA-C22.2 No. 94.1-07	-	Special Purpose Enclosures
CSA C22.2 No. 174-M1984 (R2012)	-	Cables and Cable Glands for Use in Hazardous Locations
UL 50 (Twelfth Edition)	-	Enclosures for Electrical Equipment
UL 514B (Fifth Edition)	-	Conduit, Tubing, and Cable Fittings
UL 1203 (Fourth Edition)	-	UL Standard for Safety Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Location

Notes:

Products certified under Class 4418 05, 4418 85 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca

