

## **Separation Plates for MCS MCD Enclosures, SPD**



This steel separation plate separates bayed enclosures while maintaining the IP rating, creating individual spaces for components to be mounted.

## **FEATURES**

Description: Separates two bayed MCS/MCD enclosures.

Material: 1.5 mm zinc plated steel.

Mounting requirements: IP 43 and TYPE 1 sealing can be obtained by using SPDG gasket. CCJ brackets are required to mount the SPD into the enclosures. To bay enclosures together, use CCM and CCI brackets. For EMI shielding the SPDEG gasket must be used.

Pack quantity: 1 piece.

## **SPECIFICATIONS**

Thickness: 1.5mm Material: Mild Steel Finish: Zinc Plated

Table 1/1						
Catalog Number	Article Number	Height	Width	Depth	Enclosure Material	Quick Ship
SPD2005	SPD2005	2000mm	13mm	406mm	Mild Steel	No
SPD1804	SPD1804	1800mm	13mm	306mm	Mild Steel	No
SPD2006	SPD2006	2000mm	13mm	506mm	Mild Steel	No
SPD1806	SPD1806	1800mm	13mm	506mm	Mild Steel	No
SPD2208	SPD2208	2200mm	13mm	706mm	Mild Steel	No
SPD2004	SPD2004	2000mm	13mm	306mm	Mild Steel	No
SPD2206	SPD2206	2200mm	13mm	506mm	Mild Steel	No
SPD2008	SPD2008	2000mm	13mm	706mm	Mild Steel	No
SPD1805	SPD1805	1800mm	13mm	406mm	Mild Steel	No

## **WARNING**

nVent products shall be installed and used only as indicated in nVent's product instruction sheets and training materials. Instruction sheets are available at www.nvent.com and from your nVent customer service representative. Improper installation, misuse, misapplication or other failure to completely follow nVent's instructions and warnings may cause product malfunction, property damage, serious bodily injury and death and/or void your warranty.



Our powerful portfolio of brands:

CADDY **ERICO HOFFMAN TRACHTE SCHROFF ILSCO**