

Bonding and Grounding Compression Lugs



The Compression Lugs terminate copper or tinned-copper conductors for connection to busbars, cabinets, racks, and cable runway. They are color-coded by conductor size. Installation of the Compression Lugs requires two screws (not included).

FEATURES

The Compression Lugs terminate copper or tinned-copper conductors for connection to busbars, cabinets, racks, and cable runway

They are color-coded by conductor size. Installation of the Compression Lugs requires two screws (not included)

SPECIFICATIONS

Table 1/1

Catalog Number	Article Number	Material	Finish	Thickness	Cable Size	Required Screw Size
DGCL61	17252	Copper	Electroplated, Tinned	3.5mm	#6	1/4
DGCL402	17257	Copper	Electroplated, Tinned	3.5mm	#4/0	3/8
DGCL201	17256	Copper	Electroplated, Tinned	3.5mm	#2/0	3/8
DGCL22	17255	Copper	Electroplated, Tinned	3.5mm	#2	3/8
DGCL62	17253	Copper	Electroplated, Tinned	3.5mm	#6	3/8
DGCL21	17254	Copper	Electroplated, Tinned	3.5mm	#2	1/4

WARNING

nVent products shall be installed and used only as indicated in nVent's product instruction sheets and training materials. Instruction sheets are available at www.nvent.com and from your nVent customer service representative. Improper installation, misuse, misapplication or other failure to completely follow nVent's instructions and warnings may cause product malfunction, property damage, serious bodily injury and death and/or void your warranty.



Our powerful portfolio of brands:

CADDY ERICO HOFFMAN ILSCO SCHROFF TRACHTE