

Varistar LHX+ 45 / RackChiller In-Row 45 Condensate Drain

Data Solutions

For facilities which operate at low chilled water temperatures, there is an increased risk of condensation. The condensate water will drip into the condensate tray where it will be collected. This kit enables the device to remove the condensate water into a condensate management plumbing network.

The kit is meant for installations with a condensate water pump located overhead of the cooler. It transports the water with the help of a pump above the level of the condensate tray.

00186-Varistar LHX+45-RackChiller In-Row 45 Condensate Drain-24630-178.tif

FEATURES

Provides condensate water management for facilities with low chilled water temperatures

Condensate water which collects inside the condensate tray / bottom panel of the cooler will be removed

Can be retrofitted even after cooler installation

SPECIFICATIONS

Table 1/1

Catalog Number	Package Quantity
24630-170	1
24630-178	1

WARNING

nVent products shall be installed and used only as indicated in nVent's product instruction sheets and training materials. Instruction sheets are available at www.nvent.com and from your nVent customer service representative. Improper installation, misuse, misapplication or other failure to completely follow nVent's instructions and warnings may cause product malfunction, property damage, serious bodily injury and death and/or void your warranty.



Our powerful portfolio of brands:

CADDY ERICO HOFFMAN ILSCO SCHROFF TRACHTE