

# **Bonding and Grounding Compression Lugs**

## **Data Solutions**



The Compression Lugs terminate copper or tinned-copper conductors for connection to busbars, cabinets, racks, and cable runway. They are color-coded by conductor size. Installation of the Compression Lugs requires two screws (not included).

### **FEATURES**

The Compression Lugs terminate copper or tinned-copper conductors for connection to busbars, cabinets, racks, and cable runway

They are color-coded by conductor size. Installation of the Compression Lugs requires two screws (not included)

### **SPECIFICATIONS**

Table 1/2							
Catalog Number	Article Number	Material	Finish	Thickness	Cable Size	On-Center Dimension Between Holes	
DGCL61	17252	Copper	Electroplated, Tinned	0.14in	#6	0.625in	
DGCL402	17257	Copper	Electroplated, Tinned	0.14in	#4/0	1in	
DGCL201	17256	Copper	Electroplated, Tinned	0.14in	#2/0	1in	
DGCL22	17255	Copper	Electroplated, Tinned	0.14in	#2	1in	
DGCL62	17253	Copper	Electroplated, Tinned	0.14in	#6	1in	

CatalogNumber	Article Number	Material	Finish	Thickness	Cable Size	On-Center Dimension Between Holes
DGCL21	17254	Copper	Electroplated, Tinned	0.14in	#2	0.625in

Table 2/2						
Catalog Number	Article Number	Required Screw Size				
DGCL61	17252	1/4				
DGCL402	17257	3/8				
DGCL201	17256	3/8				
DGCL22	17255	3/8				
DGCL62	17253	3/8				
DGCL21	17254	1/4				

### **WARNING**

nVent products shall be installed and used only as indicated in nVent's product instruction sheets and training materials. Instruction sheets are available at www.nvent.com and from your nVent customer service representative. Improper installation, misuse, misapplication or other failure to completely follow nVent's instructions and warnings may cause product malfunction, property damage, serious bodily injury and death and/or void your warranty.



Our powerful portfolio of brands:

**CADDY ERICO HOFFMAN SCHROFF TRACHTE ILSCO**