

# Устройство управления изолированного коридора для автоматической верхней крышки

## Data Solutions

Контроллер для автоматического открытия верхних крышек изолированного коридора.



### CERTIFICATIONS



### FEATURES

Устройство управления для 12 автоматических крышек

Входы: Требуется внешний источник питания 24 В пост. тока, заказывайте отдельно; 2 плавающих контакта для подключения к системе обнаружения пожара и другим кнопкам открытия/диагностики

Выход: Соединение 24 В пост. тока для управления и подачи напряжения на макс. 12 автоматических верхних крышек корпуса, которые можно подключить последовательно

### SPECIFICATIONS

Table 1/1

| Catalog Number | Color | Works With | Rack Height | Высота мм | Ширина мм | Package Quantity |
|----------------|-------|------------|-------------|-----------|-----------|------------------|
|----------------|-------|------------|-------------|-----------|-----------|------------------|

|           |        |                      |    |      |       |   |
|-----------|--------|----------------------|----|------|-------|---|
| 23130-205 | Черный | Aisle<br>Containment | 1U | 45mm | 450mm | 1 |
|-----------|--------|----------------------|----|------|-------|---|

ADDITIONAL PRODUCT DETAILS

Для работы системы требуется источник питания постоянного тока 24 В. Пожалуйста, закажите отдельно.

WARNING

nVent products shall be installed and used only as indicated in nVent's product instruction sheets and training materials. Instruction sheets are available at [www.nvent.com](http://www.nvent.com) and from your nVent customer service representative. Improper installation, misuse, misapplication or other failure to completely follow nVent's instructions and warnings may cause product malfunction, property damage, serious bodily injury and death and/or void your warranty.



Our powerful portfolio of brands:

CADDY   ERICO   HOFFMAN   ILSCO   SCHROFF   TRACHTE