

Inspection Housing, Full Seal Kit Assembly



FEATURES

Prevents the ingress of ground water into and surrounding the inspection housing

Waterproofing is achieved by enclosing an upper section of copper-bonded ground rod within a plastic pipe with seals located on both sides of the concrete pour

The two plate-style flange serves to reduce pressure, which may occur from the capillary effect of water on the outside of the seal and inspection housing

The flanges are intended to prevent water pressure from "popping" the inspection pit out of the concrete

Delivered as a kit, including a 3.9 foot (1.2 meter) PVC pipe, to be adjusted to site conditions

SPECIFICATIONS

Table 1/2

Catalog Number	Article Number	Material	Длина мм (L)	Width (W)	Глубина мм (D)	A
WGRS200	158922	Thermoplastic	248mm	248 mm	1400mm	210 mm


Table 2/2

Catalog Number	Article Number	Diameter (Ø)	Water Pressure	Working Load (F)	Unit Weight
WGRS200	158922	350 mm	550 kPa Max	6000N	4.3 kg

ADDITIONAL PRODUCT DETAILS

For use with 5/8" ground rods only.

DIAGRAMS



WARNING

nVent products shall be installed and used only as indicated in nVent's product instruction sheets and training materials. Instruction sheets are available at www.nvent.com and from your nVent customer service representative. Improper installation, misuse, misapplication or other failure to completely follow nVent's instructions and warnings may cause product malfunction, property damage, serious bodily injury and death and/or void your warranty.

North America

+1.800.753.9221
Option 1 – Customer Care
Option 2 – Technical
Support

Europe

Netherlands:
+31 800-0200135
France:
+33 800 901 793

Europe

Germany:
800 1890272
Other Countries:
+31 13 5835404

APAC

Shanghai:
+ 86 21 2412 1618/19
Sydney:
+61 2 9751 8500



Our powerful portfolio of brands:

CADDY ERICO HOFFMAN ILSCO SCHROFF TRACHTE