



Certificate of Compliance

Certificate: 2552929 **Master Contract:** 165122
Project: 80212754 **Date Issued:** 2024-07-22
Issued to: IIsco Corporation
4701 Creek Road
Suite 110
Cincinnati, Ohio 45242
United States
Attention: Tonson Tong

The products listed below are eligible to bear the CSA Mark shown



Issued by: Tim Gentry
Tim Gentry

PRODUCTS

Class 4414 04 FITTINGS - Grounding and Bonding Equipment

Grounding Clamps, for use with copper conductor

Model(s)
Cat No GPL3902BU, Cat No GPL3903BU, Cat No GPL3904BU, Cat No GPL3905BU, Cat No GPL3906BU, Cat No GPL3907BU, Cat No GPL3908BU, Cat No GPL3909BU, Cat No GPL3902SSBU, Cat No GPL3903SSBU, Cat No GPL3904SSBU, Cat No GPL3905SSBU, Cat No GPL3906SSBU, Cat No GPL3907SSBU, Cat No GPL3908SSBU, Cat No GPL3909SSBU
Cat. No. GPL-1, Cat. No. GPL-2, Cat. No. GPL-3, Cat. No. GPL-4, Cat. No. GPL-5, Cat. No. GPL-6, Cat. No. GPL-7, Cat. No. GPL-8, Cat. No. GPL-9, Cat. No. GPL-10, Cat. No. GPL-12, Cat. No. GPL-14, Cat. No. GPL-15, Cat. No. GPL-16, Cat. No. GPL-17, Cat. No. GPL-20, Cat. No. GPL-21, Cat. No. GPL-22, Cat. No. GPL-23, Cat. No. GPL-26, Cat. No. GPL-27, Cat. No. GPL-28, Cat. No. GPL-29, Cat. No. GPL-32, Cat. No. GPL-33, Cat. No. GPL-34, Cat. No. GPL-35, Cat. No. GPL-38, Cat. No. GPL-39, Cat. No. GPL-40, Cat. No. GPL-41, Cat. No. GPL-44, Cat. No. GPL-45, Cat. No. GPL-46, Cat. No. GPL-47, Cat. No. GPL-50, Cat. No. GPL-51, Cat. No. GPL-52, Cat. No. GPL-53, Cat. No. GPL-56, Cat. No. GPL-57, Cat. No. GPL-58, Cat. No. GPL-59, Cat. No. GPL-68, Cat. No. GPL-69, Cat. No. GPL-70, Cat. No. GPL-71, Cat. No. GPL-75, Cat. No. GPL-76, Cat. No. GPL-77
ULT-1, ULT-2, ULT-3, ULT-4, ULT-5, ULT-6, ULT-7, ULT-8, ULT-9, ULT-10, ULT-11, ULT-12
Cat No BGRC-48, Cat No BGRC-58, Cat No BGRC-68, Cat No SRC-1/0, CGRC-48, CGRC-58, CGRC-68



Certificate: 2552929

Master Contract: 165122

Project: 80212754

Date Issued: 2024-07-22

XT-4

Conditions of Acceptability:

1. Supplied only to manufacturers, as components, for assembly to Certified electrical equipment, where the suitability of the combination is to be determined in the end use by CSA Group.
2. These grounding connectors are to be installed using the proper tooling and in accordance with the requirements of the Canadian Electrical Code, Part 1.
3. Grounding clamps are pre-filled with oxide inhibiting compound and are suitable for direct burial in earth or concrete.
4. Series GPL3900 grounding clamps are intended for the connection of metal conduit, pipe, tubing or post.
5. Series GPL grounding clamps are intended for the connection of IPS tube, pipe, or rod.
6. ULT Series are certified only for use with appropriate crimping tools described in this report.

APPLICABLE REQUIREMENTS

CSA C22.2 NO. 41-13 (Sixth Edition) (R2017) - Grounding and bonding equipment



Certificate: 2552929


Project: 80212754

Master Contract: 165122

Date Issued: 2024-07-22

Notes:

Products certified under Class(es) C441404 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Certificate of Compliance

Certificate: 2134712 (LR 29601)

Master Contract: 165122

Project: 2134712

Date Issued: 2009/02/11

Issued to: IlSCO Corporation

4730 Madison Rd
Cincinnati, OH 45227
USA

Attention: Donald J. Smiley

The products listed below are eligible to bear the CSA Mark shown



Issued by: Nick Sajatovich

Authorized by: Nick Alfano, Operations
Manager

PRODUCTS

CLASS 6223 02 - WIRE CONNECTING DEVICES - Wire Connectors

CLASS 4414 04 - GROUNDING AND BONDING DEVICES

Grounding wire connector, Cat. No. GBT-1/0 (G1033), GBT-250 (G1034) and GBT-1/0-M (G1036).

Wire connector, Cat. No. D3877, AL9CU rating, for wire sizes 350 kcmil - 6AWG copper and aluminum conductors.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 41 - Grounding and Bonding Equipment.

CSA Standard C22.2 No. 65 - Wire Connectors.



Certificate of Compliance

Certificate: 1138210

Master Contract: 165122

Project: 80119140

Date Issued: 2022-04-06

Issued To: IlSCO Corporation
4730 Madison Rd
Cincinnati, Ohio, 45227
United States

Attention: Tonson Tong

The products listed below are eligible to bear the CSA Mark shown



Issued by: Minoru Morimoto
Minoru Morimoto, C.E.T.

PRODUCTS

CLASS 4414 04 - FITTINGS Grounding and Bonding Equipment

Grounding Connectors, for use with 4 to 14 AWG solid and stranded copper conductors, Cat Nos:

- GBL-4DB (G0977)
- GBL-4DBT (G0977)
- GBL-4DB-14 (G1035)
- GBL-4DBT-14 (G1035)

Note: These devices may be used for direct burial applications.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No 41-13 - Grounding and Bonding Equipment




Certificate: 1138210
Project: 80119140

Master Contract: 165122
Date Issued: 2022-04-06

Notes:

Products certified under Class C441404 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Certificate of Compliance

Certificate: 2429280

Master Contract: 165122 (LR 29601)

Project: 70170984

Date Issued: 2018-02-15

Issued to: **IlSCO Corporation**
4730 Madison Rd
Cincinnati, Ohio 45227
USA

Attention: Tonson Tong

The products listed below are eligible to bear the CSA Mark shown



Michael Chung
Issued by: Michael Chung

PRODUCTS

CLASS 4414 04 - GROUNDING AND BONDING DEVICES

Grounding Connectors, Cat Nos SGB-4, SGB-5, for solid/stranded copper conductor, sizes 4-14 AWG and solid/stranded aluminum conductor, sizes 4-12 AWG; Cat No SGB-1/0, for solid/stranded copper conductor, sizes 1/0-14 AWG and solid/stranded aluminum conductor, sizes 1/0-12 AWG; Cat No SGB-250 for stranded copper conductor, sizes 250-6 kcmil/AWG and stranded aluminum conductor, sizes 250-6 kcmil/AWG.

Grounding Connectors, Cat No C followed by S or L, followed by N or W, followed by S, D, F, B, N or U, may or may not be followed by -10, for use with 10-14AWG stranded copper conductor and 10-12AWG solid copper conductor.

Copper Grounding Clamps Cat. Nos. GTGC-6-1/0, GTGC-2-2/0 and GTGC-2/0-250 suitable for direct burial.

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No 41-13 - Grounding and Bonding Equipment