

SOPEMEA SAS Groupe APAVE
Laboratoire de Conformité Electrique
27 Rue de l'avenir,
FR-69740 Genas FRANCE

NVENT

Rue Charles Dalli re BP31
42161 Andr zieux-Bouth on Cedex France
A l'attention de / To : Mr Pascal GODARD

**DOCUMENT DE SYNTHESE /
SYNTHESIS DOCUMENT**

1E43811-04

**ERIFLEX FLEXBUS SPLICING BLOCK
CONFORMITY ASSESMENT OF CLASS II CONSTRUCTION / EVALUATION DE LA
CONSTRUCTION DE CLASSE II**

1. PORTEE DE CE DOCUMENT / SCOPE OF THIS DOCUMENT

Le pr sent document constitue la synth se du rapport 1E43811-02 qui donne le d tail des r sultats des contr les et r alis s sur le produit / The present document constitutes the synthesis of the report 1E43811-02. which gives the details of inspections and test achieved on the product.

2. PRODUIT CONCERNE / CONCERNED PRODUCT

Echantillon test�: <i>Test item:</i>	SPLICING BLOCK	Tension nominale <i>Rated voltage</i>	1000VAC, 1500VDC
Marque: <i>Trade Mark</i>	nVENT	R�gime de neutre (classe II) <i>Neutral position (Class II)</i>	All
Identification / Typ-No: <i>Identification / Type No.:</i>	ERIFLEX FLEXBUS SPLICING BLOCK Type N� : 508163 / 508164 / 508165 / 508166 / 508167	Num�ro de s�rie <i>Serial number</i>	/

3. OBJECTIF DE LA MISSION / SCOPE OF THE MISSION (voir les d tails dans le rapport / See details in test report)

Sp cification(s) de test:
Test specification: Evaluation de la conformit  du produit et de son dossier technique aux documents suivants : / *Conformity assessment of the product and its technical file to the following documents :*
  8.4.4 of IEC 61439-1 :2021

4. CONCLUSION DU RAPPORT / TEST REPORT CONCLUSION

La conclusion du rapport montre que le produit examine est conforme aux prescriptions de (des) documents(s) de r f rence. / *The conclusion of the test report shows that the examined product comply with the prescriptions of the reference documents.*

S MANDRAY / Ing nieur Conformit 
16/04/2025
**Limite de validit  / Limit of validity : 3 ans / 3
years**

mandray

