

Announcement N° CC13021: ERIFLEX FLEXIBAR ADVANCED, IBS & IBSB ADVANCED and FLEXBUS

Date: December 14th, 2021


We, nVent, confirm that ERIFLEX FLEXIBAR ADVANCED, IBS & IBSB ADVANCED and FLEXBUS pass the Glow Wire Test at 960°C according to IEC® 60695-2-12 requirements.

Best Regards,

Emmanuel Duc
Engineering Manager

nVent
ERICO SARL
Rue Charles Dallière BP31
42161 Andrézieux Bouthéon Cedex
France

ERICO® France SARL
Rue Charles Dallière
Z.I. Sud - BP 31
42161 ANDRÉZIEUX Cedex
FRANCE Tel: 04 77 36 56 56
Télécopie: 04 77 55 37 89



WARNING:

1. nVent products shall be installed and used only as indicated in nVent product instruction sheets and training materials. Instruction sheets are available at www.nVent.com and from your nVent customer service representative.
2. nVent products must never be used for a purpose other than the purpose for which they were designed or in a manner that exceeds specified load ratings.
3. All instructions must be completely followed to ensure proper and safe installation and performance.
4. Improper installation, misuse, misapplication or other failure to completely follow nVent's instructions and warnings may cause product malfunction, property damage, serious bodily injury and death. The customer is responsible for:
 - a. Conformance to all governing codes.
 - b. The integrity of structures to which the products are attached, including their capability of safely accepting the loads imposed, as evaluated by a qualified engineer.
 - c. Using appropriate industry standard hardware as noted above.

SAFETY INSTRUCTIONS:

All governing codes and regulations and those required by the job site must be observed
Always use appropriate safety equipment such as eye protection, hard hat, and gloves as appropriate to the application.