

Declaration of Conformity

nVent ERICO declares that the following products comply with the technical requirements specified below.

Equipment Description: EarthBridges made with nVent ERICO Cadweld connections

Product Name: DB10C50S050H, DB10C70S050H, DB10K16P050H, DB12K16P050H, DB16K16P050H, DB10K16S050H, DB10K16S050HG, DB12K16S050H, DB16K16S050H, DB16N70P050TA, DB16N95P050TA, DB16N70S300ES, DB16N70S050TA, DB16N95S050TA, DB10C50S100HC, DB10K16P050HG, DB12K16P050HG, DB12K16S050HG, DB16N70S050C, DB16N70S100C, DB16N95S050C, DB16N95S100C, DB16T40P040C, BF10C50S050H, BF10K12P050H, BF12K12P050H, BF12K12P050HG, BF10K12S050H, BF12K12S050H, BF12K16S050H, BF10C50S100HC, BT12C50S050HC, BT50C70S100SRC, BT12K16S050HG, TA40N95S100TAC, TA40N95S050TAC

Business Trade Mark/Brand Name: nVent ERICO

Applicable Standards : EN IEC 62561-1:2017

Ratings: For General use
Class H for Heavy Duty (100kA)

Test Report: 31979; December 20, 2020

Authorized by:



Ward Judson

Engineering Manager

Date

November 5th, 2021